



MAHATMA PHULE KRISHI VIDYAPEETH

Office of the University Engineer

Rahuri 413 722 (Dist-Ahmednagar)

(MAHARASHTRA)

Phone 02426 243 272 (Office), 02426 243235 (fax)

No. MPKV/UE/555/2017

Dated: 20/05/2017

Subject: Regarding clarification of tender condition, Letter of Shrinath construction.

| Sr.No. | Point raised by contractor | Clarification |
|--------|---|--|
| 1 | Issue the interest free mobilization advance @20% of contract value. | No mobilization advance will be given |
| 2 | Solvency certificate 20% | Solvency certificate in current financial year is required solvency certificate of 40 % cost tender cost of project is required. |
| 3 | Plant and machinery on hire basis | Own Plant and machinery condition is a specific requirement of University for this most prestigious project. |
| 4 | Provide Excel copy of BOQ for working | Only pdf copy will be available |
| 5 | 3.3 (7) mentioned that Net cash accruals from operations for each of last 3 year; at least 7 carore certified by C.A. turnover criteria demanded maximum turnover in last 3 years Rs. 9.0 Carore; it will not possible to have cash accruals of 7 caror with demanded turnover. | Criteria is cancelled |
| 6 | Allow low KVA Electrical generator instead of 250 KVA | 250 KVA generator is required |
| 7 | How many of Rs. Additional Security Deposit for Plant & Machinery is required | Rs. 5.0 Lakhs |

University Engineer

MPKV, Rahuri